

Cyber Security (CSWG) Assessment of PAP-05

Status: Approved

Were CSWG requirements met? Yes

Comments: The AEIC Metering Guidelines referenced interoperability requirements based on the ANSI C12 suite. The CSWG review identifies issues with the referenced ANSI C12 suite in regard to gaps in cybersecurity. The CSWG recommends that the ANSI C12 suite be reviewed by a future PAP and/or DEWG to ensure cybersecurity requirements are adequately addressed.